



**NOTES:**

1. TRENCH SHALL BE BACKFILLED AND COMPACTED IN ACCORDANCE WITH WSDOT 7-09.3(10) & (11) OR AS APPROVED IN WRITING BY THE CITY ENGINEER.
2. BEDDING (IF REQUIRED BY THE CITY), SHALL CONFORM TO WSDOT 7-09.3(9).
3. BACKFILL MATERIAL SHALL BE GRAVEL BORROW OR SELECT BORROW IN ACCORDANCE WITH WSDOT 9-03.14 OR 1 1/4" CRUSHED ROCK OR AS APPROVED IN WRITING BY THE CITY ENGINEER.

1	Added Note 3.	8/3/11
Rev. No.	Revisions	Date

Approved: *[Signature]* June 17, 2005  
 City Engineer Date

**WATER STANDARD DETAIL**



Dwg No:

**W2**

**WATER MAIN  
TRENCH SECTION**